

Beta Fire & Safety

Fire Extinguisher Survey Report

73 Frimley House,
5 The Parade, High Street
Frimley, Surrey
GU16 7JQ.
01252 - 260 - 025

Customer name:

Page 1 of 1

Site address:

Site contact:

No	Fl	Location	W	F	C	P	Wc	Fb	Hr	Co/Sp	Extended Test Date	Comments
1	G	Main Entrance - Reception		6						Sp	2013	Discharge tested
2	G	Main Entrance - Reception			2					-	2018	Recharged
3	1	Stairwell - Outside Accounts		6						Co	2009	Due test in 2009
4	1	Stairwell - Outside Accounts			2					-	2009	Due test in 2009
5	1	Inside Accounts Office			2					-	2010	-
6	R	Roof Lift Motor Room				6				Sp	2012	-
7	R	Roof Lift Motor Room			2					-	2012	-

Sample - Document is Provided in Printed Electronic Format.

Up to 25 extinguishers can be listed per page.

Index: No = extinguisher number. Fl = floor level. Location = extinguisher siting location. W = water. F = foam. C = carbon dioxide. P = dry powder. Wc = wet chemical. Fb = fire blanket. Hr = hose reel. Co = cartridge operated. Sp = stored pressure. Extended test date = date extinguisher is due 5 or 10 yearly discharge test. Comments = relevant info added if required. Numbers in columns = size in litres or kilos of extinguisher - e.g. 6 = 6 litre foam or 6 kg dry powder etc...